JAXSON SUSPENDED



This product must be installed in accordance to the national electrical code and all applicable local codes. Failure to do so may result in serious injuries. Proper grounding is required for safety. Do not install if product appears to be damaged.



Included Hardware:

- A:Luminaire
- B: Canopy

C: Pre-Installed Suspension Cable Locks

D: Suspension Cable Anchors

E: Suspension Cables

F: Pass-Through and Threaded Tube Assembly

- G: Pass-Through Set Screw
- H: Crossbar

Required Tools and Hardware:

- Driver
- Pen
- Laser Line Level
- Level
- Drill
- Wire Stripper
- 5/64" Hex Key
- Drywall Cutting Tool
- Cutting Pliers
- Wire Connectors
- Screws
- Anchors (If Necessary)

Suspension Kits Requirements Chart

Luminaire Length	Number of Suspension Kits Required
152 to 2438mm 6 to 96"	2 Kits
2463 to 5181mm 97 to 204"	3 Kits
5207 to 6705mm 205 to 264"	4 Kits



TOLL FREE 1 866 586 3692 TEL. 514 286 0227 info@lumenwarm.com OFFICE AND SHOWROOM 155 Fortin Street, Suite 180, Quebec City, QC G1M 3M2, Canada

JAXSON SUSPENDED



This product must be installed in accordance to the national electrical code and all applicable local codes. Failure to do so may result in serious injuries. Proper grounding is required for safety. Do not install if product appears to be damaged.



Instructions:

	Tu

1	Turn power off.	2	Install <i>Driver</i> in desired location and bring power cord to the location of <i>Luminaire</i> (A).
3	Measure and mark location of <i>Canopy</i> (B). It should be placed where the main power lines are as well as aligned with the <i>Luminaire</i> (A) power cord.	4	Prepare access to main power lines as needed.
5	If necessary, untighten S <i>uspension Cable Locks</i> (C), slide them to desired locations and retighten.	6	While aligned with S <i>uspension Cable Locks</i> (C), mark placement of S <i>uspension Cable Anchors</i> (D).
7	Unscrew Suspension Cables (E) from Suspension Cable Anchors (D) and screw Anchors (D) securely to surface before screwing Supsension Cables (E) back in place.	8	Insert Suspension Cables (E) in Supsension Cable Locks (C) through the unscrewed pin. Make sure Luminaire (A) is leveled and cut excess Suspension Cables (D) if needed once the Suspension Cable Locks (C) pin has been retightened.
9	Insert power cord through Pass-Through and Threaded Tube Assembly (F), Canopy (B) and Crossbar (K) in this order, Pass-Through first.	10	Adjust power cord length between <i>Canopy</i> (B) and <i>Luminaire</i> (A). If needed, cut and strip power cord.
	Using Wire Connectors, connect the stripped		Screw Threaded Tube of the Pass-Through and

- M Threaded Tube Assembly (F) into Crossbar (H) until Canopy (B) rests on the surface.
- Screw Pass-Through Set Screw (G) into Pass-Through and Threaded Tube Assembly (F). Do NOT damage power cord.





Do not overload power unit if many Luminaires are connected to the same one.





cables to Driver.

TEL. 514 286 0227 info@lumenwarm.com OFFICE AND SHOWROOM 155 Fortin Street, Suite 180, Quebec City, QC G1M 3M2, Canada